

# **MULTIS L50**

# Digital panel meter

three phases - via CT up to 6000 A dimensions 96 x 96 mm







# Function

The MULTIS L50 is a panel mounted digital meter displaying multi-measurement and energy values directly on its large backlit LCD display. It is designed for utilisation on three-phase or single-phase networks with connection via CT and is suitable for applications of up to 6000 A. The product can be configured by the user via the keypad and the display.

# Advantages

#### Easy to use

Thanks to its large backlit LCD display and its multiple viewing screens with direct pushbutton access, MULTIS L50 provide clear readings and are easy to use. They directly display a number of multimeasurement and metering values.

#### Advanced functionalities

The MULTIS L50 offers input/output functions as standard and has a pulse output or RS485 MODBUS communication output.



# The solution for

> Industry

# > Infrastructure



# Strong points

- Large backlit LCD display
- > Direct display of multimeasurement and metering values
- > RS485 MODBUS communication
- > Inputs/Output for control/ command ou pulses

#### **Conformity to standards**

> IEC 62053-21 class 1 > IEC 62053-23 class 2



**Functions** 

#### Multi-measurement

- Currents
- instantaneous: I1, I2, I3, In
- maximum average: I1, I2, I3, In Voltages & frequency
- instantaneous: V1, V2, V3, U12, U23, U31, F Power
- instantaneous: 3P, ΣP, 3Q, ΣQ, 3S, ΣS
- maximum average: ΣP, ΣQ, ΣS
- unbalance: U unb
- Power factors
- instantaneous: 3PF,  $\Sigma$

# Metering

- Active energy: ± kWh
- Reactive energy: ± kvarh Hours: O

### Harmonic analysis

- Total harmonic distortion (level 51)
- Currents: thd I1, thd I2, thd I3
- Phase-to-neutral voltage: thd V1, thd V2, thd V3 - Phase-to-phase voltage: thd U12, thd U23, thd U31

#### Communications<sup>(1)</sup>

RS485 with MODBUS protocol Output

- Remote command of device
- Pulse report
- Inputs
- Remote status device
- (1) Available as an option (see the following pages).





# **MULTIS L50**

#### Digital panel meter three phases - via CT up to 6000 A dimensions 96 x 96 mm

#### Front panel



#### 1. Backlit LCD display.

- 2. Direct access key for currents (instantaneous and max. values), current THD.
- 3. Direct access key for voltages, frequency and voltage THD.
- Pushbutton for active, reactive, and apparent power (instantaneous and max. values) and power factor.
- 5. Direct access key for energies, hour meter and programming menu.

#### Case



Туре	panel mounting
Dimensions W x H x D	96 x 96 x 60 mm
Case degree of protection	IP30
Front degree of protection	IP52
Display type	backlit LCD display
Terminal block type	fixed or plug-in
Voltage and other connection cross-section	0.2 2.5 mm <sup>2</sup>
Current connection cross-section	0.5 6 mm <sup>2</sup>
Weight	400 g

# Plug-in modules

# MULTIS L50

diris\_773\_a\_1\_cat









## 1 Output

1 output assignable to:

- Pulses: configurable (type, weight, duration) in kWh or kvarh.
- Remote command of device.

#### Communication

RS485 link with JBUS / MODBUS protocol (speed up to 38400 bauds)

#### 3 inputs, 1 output

- 3 inputs assignable to:
- Remote status device.
- 1 output assignable to:
- Pulses: configurable (type, weight, duration) in kWh or kvarh.Remote command of device.

#### Accessories

Current transformers (See page 584)







IP65 protection

Panel mounting kit for a 144 x 96 mm cut-out



# **MULTIS L50** Digital panel meter three phases - via CT up to 6000 A dimensions 96 x 96 mm

# Electrical characteristics

Via CT primary9 999 AVia CT secondary5 AMeasurement range0 11 kAInput consumption0.6 VAMeasurement updating period1 sAccuracy1%Permanent overload6 AIntermittent overload10 ln for 1 sVoltage measurements (TRMS)Direct measurement between phases50 500 VACDirect measurement between phase and neutral28 289 VACInput consumption $\leq 0.1 VA$ Measurement overload1 sAccuracy1%Permanent overload800 VACPower measurement1 sAccuracy1%Power factor measurement1 sAccuracy1%Power factor measurement1 sAccuracy1%Power factor measurement1 sMeasurement updating period1 sAccuracy1%Prequency measurement1 sMeasurement updating period1 sAccuracy1%Prequency measurement1 sMeasurement updating period1 sAccuracy1%Frequency measurement1 sMeasurement range45 65 HzMeasurement updating period1 s		
Via CT secondary5 AMeasurement range0 11 kAInput consumption0.6 VAMeasurement updating period1 sAccuracy1%Permanent overload6 AIntermittent overload10 ln for 1 sVoltage measurements (TRMS)Direct measurement between phases50 500 VACDirect measurement between phase and neutral28 289 VACInput consumption $\leq 0.1$ VAMeasurement overload1 sAccuracy1%Permanent overload800 VACPower measurement1 sMeasurement updating period1 sAccuracy1%Power factor measurement1 sMeasurement updating period1 sAccuracy1%Power factor measurement1 sMeasurement updating period1 sAccuracy1%Prequency measurement1 sMeasurement updating period1 sAccuracy1%Frequency measurement1 sMeasurement updating period1 sAccuracy1%Frequency measurement1 sMeasurement range45 65 HzMeasurement updating period1 s	Current measurement (TRMS)	
Measurement range   0 11 kA     Input consumption   0.6 VA     Measurement updating period   1 s     Accuracy   1%     Permanent overload   6 A     Intermittent overload   10 In for 1 s     Voltage measurements (TRMS)   0 In for 1 s     Direct measurement between phases   50 500 VAC     Direct measurement between phase and neutral   28 289 VAC     Input consumption   ≤ 0.1 VA     Measurement updating period   1 s     Accuracy   1%     Permanent overload   800 VAC     Power measurement   800 VAC     Power measurement   1 s     Accuracy   1%     Permanent updating period   1 s     Accuracy   1%     Power factor measurement   1 s     Measurement updating period   1 s     Accuracy   1%     Frequency measurement   1 s     Measurement updating period   1 s     Measurement range   45 65 Hz     Measurement updating period   1 s	Via CT primary	9 999 A
Input consumption0.6 VAInput consumption0.6 VAMeasurement updating period1 sAccuracy1%Permanent overload6 AIntermittent overload10 In for 1 sVoltage measurements (TRMS)Direct measurement between phases50 500 VACDirect measurement between phase and neutral28 289 VACInput consumption $\leq 0.1 VA$ Measurement updating period1 sAccuracy1%Permanent overload800 VACPower measurement800 VACPower measurement1 sAccuracy1%Power factor measurement1 sMeasurement updating period1 sAccuracy1%Power factor measurement1 sMeasurement updating period1 sAccuracy1%Power factor measurement1 sMeasurement updating period1 sAccuracy1%Frequency measurement45 65 HzMeasurement range45 65 HzMeasurement updating period1 s	Via CT secondary	5 A
Measurement updating period1 sAccuracy1%Permanent overload6 AIntermittent overload10 ln for 1 sVoltage measurements (TRMS)Direct measurement between phases50 500 VACDirect measurement between phase and neutral28 289 VACInput consumption $\leq 0.1 VA$ Measurement updating period1 sAccuracy1%Permanent overload800 VACPower measurement1 sAccuracy1%Power factor measurement1 sMeasurement updating period1 sAccuracy1%Power factor measurement1 sMeasurement updating period1 sAccuracy1%Power factor measurement1 sMeasurement updating period1 sAccuracy1%Frequency measurement45 65 HzMeasurement range45 65 HzMeasurement updating period1 s	Measurement range	0 11 kA
Accuracy $1\%$ Permanent overload $6 A$ Intermittent overload $10 I_n$ for 1 sVoltage measurements (TRMS)Direct measurement between phases $50 \dots 500 \text{ VAC}$ Direct measurement between phase and neutral $28 \dots 289 \text{ VAC}$ Input consumption $\leq 0.1 \text{ VA}$ Measurement updating period $1 \text{ s}$ Accuracy $1\%$ Permanent overload $800 \text{ VAC}$ Power measurement $1 \text{ s}$ Accuracy $1\%$ Power factor measurement $1 \text{ s}$ Accuracy $1\%$ Power factor measurement $1 \text{ s}$ Accuracy $1\%$ Frequency measurement $1 \text{ s}$ Measurement updating period $1 \text{ s}$ Accuracy $1\%$ Power factor measurement $1 \text{ s}$ Measurement updating period $1 \text{ s}$ Accuracy $1\%$ Frequency measurement $1 \text{ s}$ Measurement range $45 \dots 65 \text{ Hz}$ Measurement updating period $1 \text{ s}$	Input consumption	0.6 VA
Permanent overload $6 \text{ A}$ Intermittent overload $10 \text{ I}_n$ for 1 sVoltage measurements (TRMS)Direct measurement between phases $50 \dots 500 \text{ VAC}$ Direct measurement between phase and neutral $28 \dots 289 \text{ VAC}$ Input consumption $\leq 0.1 \text{ VA}$ Measurement updating period $1 \text{ s}$ Accuracy $1\%$ Permanent overload $800 \text{ VAC}$ Power measurement $1 \text{ s}$ Accuracy $1\%$ Power factor measurement $1 \text{ s}$ Accuracy $1\%$ Power factor measurement $1 \text{ s}$ Accuracy $1\%$ Frequency measurement $1 \text{ s}$ Measurement updating period $1 \text{ s}$ Accuracy $1\%$ Power factor measurement $1 \text{ s}$ Measurement updating period $1 \text{ s}$ Accuracy $1\%$ Frequency measurement $1 \text{ s}$ Measurement range $45 \dots 65 \text{ Hz}$ Measurement updating period $1 \text{ s}$	Measurement updating period	1s
Intermittent overload10 In for 1 sVoltage measurements (TRMS)Direct measurement between phases $50 \dots 500 \text{ VAC}$ Direct measurement between phase and neutral $28 \dots 289 \text{ VAC}$ Input consumption $\leq 0.1 \text{ VA}$ Measurement updating period1 sAccuracy $1\%$ Permanent overload800 VACPower measurement1 sAccuracy $1\%$ Permanent overload1 sAccuracy $1\%$ Power factor measurement1 sMeasurement updating period1 sAccuracy $1\%$ Prequency measurement1 sMeasurement updating period1 sAccuracy $1\%$ Prequency measurement1 sMeasurement updating period1 sAccuracy $1\%$ Frequency measurement $1\%$ Measurement range $45 \dots 65 \text{ Hz}$ Measurement updating period1 s	Accuracy	1%
Voltage measurements (TRMS)     Direct measurement between phases   50 500 VAC     Direct measurement between phase and neutral   28 289 VAC     Input consumption   ≤ 0.1 VA     Measurement updating period   1 s     Accuracy   1%     Permanent overload   800 VAC     Power measurement   1 s     Measurement updating period   1 s     Accuracy   1%     Power factor measurement   1 s     Measurement updating period   1 s     Accuracy   1%     Power factor measurement   1 s     Measurement updating period   1 s     Accuracy   1%     Frequency measurement   1 s     Measurement range   45 65 Hz     Measurement updating period   1 s	Permanent overload	6 A
Direct measurement between phases   50 500 VAC     Direct measurement between phase and neutral   28 289 VAC     Input consumption   ≤ 0.1 VA     Measurement updating period   1 s     Accuracy   1%     Permanent overload   800 VAC     Power measurement   300 VAC     Power measurement   1 s     Accuracy   1%     Power factor measurement   1 s     Measurement updating period   1 s     Accuracy   1%     Power factor measurement   1%     Measurement updating period   1 s     Accuracy   1%     Frequency measurement   1%     Measurement updating period   1 s     Accuracy   1%     Frequency measurement   45 65 Hz     Measurement range   45 65 Hz     Measurement updating period   1 s	Intermittent overload	10 l <sub>n</sub> for 1 s
Direct measurement between phase and neutral   28 289 VAC     Input consumption   ≤ 0.1 VA     Measurement updating period   1 s     Accuracy   1%     Permanent overload   800 VAC     Power measurement   800 VAC     Power measurement   1 s     Measurement updating period   1 s     Accuracy   1%     Power factor measurement   1%     Measurement updating period   1 s     Accuracy   1%     Frequency measurement   1%     Measurement range   45 65 Hz     Measurement updating period   1 s	Voltage measurements (TRMS)	
Input consumption   ≤ 0.1 VA     Measurement updating period   1 s     Accuracy   1%     Permanent overload   800 VAC     Power measurement   800 VAC     Measurement updating period   1 s     Accuracy   1%     Power factor measurement   1%     Measurement updating period   1 s     Accuracy   1%     Frequency measurement   1%     Measurement range   45 65 Hz     Measurement updating period   1 s	Direct measurement between phases	50 500 VAC
Measurement updating period   1 s     Accuracy   1%     Permanent overload   800 VAC     Power measurement   800 VAC     Power measurement   1 s     Measurement updating period   1 s     Accuracy   1%     Power factor measurement   1%     Measurement updating period   1 s     Accuracy   1%     Frequency measurement   1%     Measurement range   45 65 Hz     Measurement updating period   1 s	Direct measurement between phase and neutral	28 289 VAC
Accuracy   1%     Permanent overload   800 VAC     Power measurement   1 s     Measurement updating period   1 s     Accuracy   1%     Power factor measurement   1%     Measurement updating period   1 s     Accuracy   1%     Frequency measurement   1%     Measurement range   45 65 Hz     Measurement updating period   1 s	Input consumption	≤ 0.1 VA
Permanent overload 800 VAC   Power measurement 1 s   Measurement updating period 1 s   Accuracy 1%   Power factor measurement 4   Measurement updating period 1 s   Accuracy 1%   Frequency measurement 1%   Measurement range 45 65 Hz   Measurement updating period 1 s	Measurement updating period	1s
Power measurement Use of the second	Accuracy	1%
Measurement updating period   1 s     Accuracy   1%     Power factor measurement   1     Measurement updating period   1 s     Accuracy   1%     Frequency measurement   1%     Measurement range   45 65 Hz     Measurement updating period   1 s	Permanent overload	800 VAC
Accuracy 1%   Power factor measurement 1%   Measurement updating period 1 s   Accuracy 1%   Frequency measurement 1%   Measurement range 45 65 Hz   Measurement updating period 1 s	Power measurement	
Power factor measurement   Measurement updating period 1 s   Accuracy 1%   Frequency measurement 45 65 Hz   Measurement updating period 1 s	Measurement updating period	1s
Measurement updating period 1 s   Accuracy 1%   Frequency measurement 45 65 Hz   Measurement updating period 1 s	Accuracy	1%
Accuracy 1%   Frequency measurement 45 65 Hz   Measurement range 45 65 Hz   Measurement updating period 1 s	Power factor measurement	
Frequency measurement   Measurement range   45 65 Hz   Measurement updating period   1 s	Measurement updating period	1s
Measurement range 45 65 Hz   Measurement updating period 1 s	Accuracy	1%
Measurement updating period 1 s	Frequency measurement	
1 01	Measurement range	45 65 Hz
Accurrent 0.1.0/	Measurement updating period	1 s
Accuracy 0.1%	Accuracy	0.1 %

Energy accuracy	
Active (according to IEC 62053-21)	Class 1
Reactive (according to IEC 62053-23)	Class 2
Auxiliary power supply	
Alternating voltage	110 250 VAC
AC tolerance	± 10 %
Direct voltage	120 250 VDC
DC tolerance	± 10%
Frequency	50 / 60 Hz
Consumption	10 VA
Pulse or alarm output	
Number	1
Туре	100 VDC - 0.5 A - 10 VA
Max. number of operations	≤ 10 <sup>8</sup>
Inputs	
Number	3
Power supply	10 30 VDC
Minimum signal width	10 ms
Minimum duration between 2 pulses	18 ms
Туре	Phototransistors
Communication	
Link	RS485
Туре	2 3 half duplex wires
Protocol	MODBUS RTU
MODBUS <sup>®</sup> speed	1400 38400 bauds
Operating conditions	
Operating temperature	- 10 + 55 °C
Storage temperature	- 20 + 85 °C
Relative humidity	95 %

# Terminals



#### Communication module



RS485 link.

 $\mathbf{R} = 120 \ \Omega$ : selectable internal resistance for RS485 end of line termination.

#### Output or alarm module



#### S1 - S2: current inputs.

AUX: auxiliary power supply U<sub>s</sub>. V1, V2, V3 & VN: voltage inputs.

#### 3 inputs, 1 output module



#### Connection

#### Recommendation:

- For IT earthing systems, it is recommended that the CT secondary is not connected to earth.
- When disconnecting the DIRIS, the secondary of each current transformer must be short-circuited. This operation can be carried out automatically by a SOCOMEC PTI, an accessory which is included in this catalogue. Please consult us.

#### Low voltage balanced network





Use of 1 CT reduces by 0.5% the accuracy of the phases, the current of which is worked out by vector calculation. 1. Fuses 0.5 A gG / 0.5 A class CC.





1. Fuses 0.5 A gG / 0.5 A class CC.

1. Fuses 0.5 A gG / 0.5 A class CC.



#### Low voltage unbalanced network

#### 3/4 wires with 3 CTs





Use of 2 CTs reduces by 0.5% the accuracy of the phases, the current of which is worked out by vector calculation.

1. Fuses 0.5 A gG / 0.5 A class CC.

3 wires with 2 CTs

#### 3 wires with 2 CTs



Use of 2 CTs reduces by 0.5% the accuracy of the phases, the current of which is worked out by vector calculation.

1. Fuses 0.5 A gG / 0.5 A class CC.

#### Additional information

#### Communication via RS485 link



#### AC & DC auxiliary power supply



1. Fuses 0.5 A gG / 0.5 A class CC.

multi\_068\_a\_1\_x\_cat.eps

# References

Basic device		MULTIS L50
		Reference
MULTIS L50		192J <b>9120</b>
Optional plug-in modules		Reference
1 output		4825 <b>0080</b>
RS485 MODBUS® communication		4825 <b>0082</b>
3 inputs, 1 output		4825 <b>0083</b>
Accessories		
Description of accessories	To be ordered in multiples of	Reference
IP65 protection	1	4825 <b>0089</b>
Panel mounting kit for a 144 x 96 mm cut-out	1	4825 <b>0088</b>
Fuse holder for the protection of voltage inputs (type RM) 3 poles	4	5601 0018
Fuse holder for the protection of the auxiliary supply (type RM) 1 pole + neutral	6	5601 <b>0017</b>
Fuse type gG 10x38 0.5 A	10	6012 0000
Ferrite to be associated with communication modules	1	4899 <b>0011</b>
Current transformer range		see page 584

#### **Expert Services**

Study, definition, advice, implementation, maintenance and training... Our experts "Expert Services" offer complete support for the success of your project.



